



December 14, 2017
WCG Project No. 4528-300-58-01

Mr. Albert Tijerina
East Aurora School District 131
Director of Building and Grounds
411 Hill Avenue
Aurora, Illinois 60505

**RE: Lead Sampling in Potable Water
Oak Park Elementary School
1200 Front Street, Aurora, IL 60505**

Dear Mr. Tijerina:

The following letter report summarizes the laboratory results for the drinking water samples collected from the potable water sources at Oak Park Elementary School in Aurora, Illinois. The sampling was conducted on November 4, 2017 by Mr. David J. Kedrowski (CIH) of Weaver Consultants Group (WCG).

SCOPE OF WORK

The scope of work for this project involved collecting water samples from pre-identified water locations. The potable locations were provided to WCG by East Aurora School District 131. The collected potable water samples were then analyzed for lead by an accredited laboratory.

METHODOLOGY

WCG followed protocols set by U.S. Environmental Protection Agency (EPA) and Illinois Department of Public Health (IDPH) for testing schools for lead in drinking water. Representatives from East Aurora School District 131 confirmed the school was under normal use and ensured the water settled within the piping systems/fixtures for between eight (8) to eighteen (18) hours.

Sixty-eight (68) water samples from representative potable water locations were collected in 250 milliliter bottles. The water samples were collected as a "first draw" from each source to represent a lead concentration from water allowed to sit within the pipes or drinking reservoirs for at least eight (8) hours and not more than eighteen (18) hours. A second sample was collected from each location after a 30 second flush to represent water from within the building's localized water piping system. Potable water sources generally included drinking fountains, Nurses' Offices, Teachers' Lounges, kitchen faucets and preschool, kindergarten, and first floor classroom sinks, etc.

At the request of the District, non-potable samples were collected at the water main to the building to establish a baseline. As this is a non-potable source, the results likely do not represent water within the building system but rather sediment at the water main valve or within the sampling connections used to draw the sample. Water samples collected at each potable fixture should instead be relied upon as representative of the drinking water within the building.

Each sample was labeled with a unique sample number identifying the school. The samples were transported to Suburban Labs Incorporated (Suburban) in Geneva, Illinois. Samples were analyzed for lead content using EPA Method 200.8 "Determination of Trace Elements in Water using Inductively Coupled Plasma (ICP)/Mass Spectrometry (MS). Suburban is accredited to analyze lead in potable drinking water under the National Environmental Laboratory Accreditation Program (NELAP).

RESULTS

The results of the water sample analysis revealed that seven (7) samples of the sixty-eight (68) collected had lead concentrations above the IDPH Action Level of 2 ppb ($\mu\text{g}/\text{L}$). All sample results that exceed 5 $\mu\text{g}/\text{L}$ should be promptly reported to parents or guardians of the enrolled students as required by the Illinois Department of Public Health (IDPH).

CONCLUSIONS AND RECOMMENDATIONS

- 1) Within 7 business days of receipt of test results, schools must email all results to IDPH at DPH.LeadH20@illinois.gov. **WCG will email these results on behalf of East Aurora School District 131.**
- 2) All sample results that exceed 5 $\mu\text{g}/\text{L}$ should be promptly reported to parents or guardians of all enrolled students in writing or electronically and include:
 - The location and source exceeding 5 $\mu\text{g}/\text{L}$.
 - The USEPA website for information about lead in drinking water, <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.
- 3) Implement corrective action for fixtures greater than 2 $\mu\text{g}/\text{L}$.
- 4) Implement best practices to minimize lead concentrations in drinking water.

BEST PRACTICES

Best practices for managing elevated lead concentrations in drinking water may include implementing a water quality management plan (WQMP), establishing a routine water flushing program for potable sources daily or during periods of low occupancy or low water usage, routine maintenance to clean screens and aerators, and confirmation sampling. In addition, occupants should avoid consuming water from non-potable sources i.e. classroom or office sinks, washroom sinks, maintenance closets, etc. and hot water taps.

A summary of the sample locations and results may be found in Appendix A and the laboratory report with chain of custody sheets may be found in Appendix B. We appreciate the opportunity to assist you on this important project.

Sincerely,

Weaver Consultants Group North Central, LLC



David J. Kedrowski, CIH
Senior Project Director

APPENDIX A
Lead in Potable Water Sample Results

**Oak Park Elementary School
1200 Front Street
Aurora, IL 60505**

Oak Park Elementary School
1200 Front Street
Aurora, IL 60505

ISBE ID	Sample Date	Sample Time (12 HR Clock)	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Concentration (ug/L)
310451310222013	11/04/2017	09:27 AM	OAKP-01A	3rd Floor - Outside Room 302	DF - Drinking Fountain	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	09:27 AM	OAKP-01B	3rd Floor - Outside Room 302	DF - Drinking Fountain	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	09:30 AM	OAKP-02A	3rd Floor - Outside Room 303 - Social Worker's Bathroom	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	09:30 AM	OAKP-02B	3rd Floor - Outside Room 303 - Social Worker's Bathroom	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	09:32 AM	OAKP-03A	3rd Floor - Outside Room 307	DF - Drinking Fountain	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	09:32 AM	OAKP-03B	3rd Floor - Outside Room 307	DF - Drinking Fountain	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	09:35 AM	OAKP-04A	2nd Floor - Outside Room 203 - Nurse's Office	DF - Drinking Fountain	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	09:35 AM	OAKP-04B	2nd Floor - Outside Room 203 - Nurse's Office	DF - Drinking Fountain	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	09:38 AM	OAKP-05A	2nd Floor - Room 203 - Nurse's Office Bathroom	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	09:38 AM	OAKP-05B	2nd Floor - Room 203 - Nurse's Office Bathroom	S - Sink	11/03/2017	07:00 PM	Flush	2.65
310451310222013	11/04/2017	09:40 AM	OAKP-06A	2nd Floor - Outside Room 208	DF - Drinking Fountain	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	09:40 AM	OAKP-06B	2nd Floor - Outside Room 208	DF - Drinking Fountain	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	09:43 AM	OAKP-07A	1st Floor - Outside Boy's Bathroom	DF - Drinking Fountain	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	09:43 AM	OAKP-07B	1st Floor - Outside Boy's Bathroom	DF - Drinking Fountain	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	09:47 AM	OAKP-08A	1st Floor - Kitchen	KS - Kitchen Sink	11/03/2017	07:00 PM	First Draw	5.3
310451310222013	11/04/2017	09:47 AM	OAKP-08B	1st Floor - Kitchen	KS - Kitchen Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	09:49 AM	OAKP-09A	1st Floor - Room 30	O - Other	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	09:49 AM	OAKP-09B	1st Floor - Room 30	O - Other	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	09:52 AM	OAKP-10A	1st Floor - Across from Girl's Bathroom (34)	DF - Drinking Fountain	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	09:52 AM	OAKP-10B	1st Floor - Across from Girl's Bathroom (34)	DF - Drinking Fountain	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	09:56 AM	OAKP-11A	1st Floor - Library Entryway (Left)	DF - Drinking Fountain	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	09:56 AM	OAKP-11B	1st Floor - Library Entryway (Left)	DF - Drinking Fountain	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	09:56 AM	OAKP-12A	1st Floor - Library Entryway (Right)	DF - Drinking Fountain	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	09:56 AM	OAKP-12B	1st Floor - Library Entryway (Right)	DF - Drinking Fountain	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	09:58 AM	OAKP-13A	1st Floor - Room 19 - Classroom	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	09:58 AM	OAKP-13B	1st Floor - Room 19 - Classroom	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:00 AM	OAKP-14A	1st Floor - Room 18 - Teacher's Lounge	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:00 AM	OAKP-14B	1st Floor - Room 18 - Teacher's Lounge	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:02 AM	OAKP-15A	1st Floor - Room 17 - 1st Grade Classroom	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:02 AM	OAKP-15B	1st Floor - Room 17 - 1st Grade Classroom	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:11 AM	OAKP-16A	1st Floor - Room 16 - Reading Interventionist	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:11 AM	OAKP-16B	1st Floor - Room 16 - Reading Interventionist	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:12 AM	OAKP-17A	1st Floor - Room 15 - Speech Pathologist	S - Sink	11/03/2017	07:00 PM	First Draw	11.4
310451310222013	11/04/2017	10:12 AM	OAKP-17B	1st Floor - Room 15 - Speech Pathologist	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:18 AM	OAKP-18A	1st Floor - Room 14 - 2nd Grade Classroom	DF - Drinking Fountain	11/03/2017	07:00 PM	First Draw	4.05
310451310222013	11/04/2017	10:18 AM	OAKP-18B	1st Floor - Room 14 - 2nd Grade Classroom	DF - Drinking Fountain	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:22 AM	OAKP-19A	1st Floor - Room 12 - 2nd Grade Classroom	S - Sink	11/03/2017	07:00 PM	First Draw	12.5
310451310222013	11/04/2017	10:22 AM	OAKP-19B	1st Floor - Room 12 - 2nd Grade Classroom	S - Sink	11/03/2017	07:00 PM	Flush	8.81
310451310222013	11/04/2017	10:28 AM	OAKP-22A	1st Floor - Room 10 - 2nd Grade Classroom	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:28 AM	OAKP-22B	1st Floor - Room 10 - 2nd Grade Classroom	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:31 AM	OAKP-23A	1st Floor - Between Boy's (9C) and Girl's (9D) Bathrooms (Left)	DF - Drinking Fountain	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:31 AM	OAKP-23B	1st Floor - Between Boy's (9C) and Girl's (9D) Bathrooms (Left)	DF - Drinking Fountain	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:31 AM	OAKP-24A	1st Floor - Between Boy's (9C) and Girl's (9D) Bathrooms (Right)	DF - Drinking Fountain	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:31 AM	OAKP-24B	1st Floor - Between Boy's (9C) and Girl's (9D) Bathrooms (Right)	DF - Drinking Fountain	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:34 AM	OAKP-25A	1st Floor - Room 9 - Kindergarten Classroom	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:34 AM	OAKP-25B	1st Floor - Room 9 - Kindergarten Classroom	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:35 AM	OAKP-26A	1st Floor - Room 8 - Kindergarten Classroom	S - Sink	11/03/2017	07:00 PM	First Draw	ND

Oak Park Elementary School
1200 Front Street
Aurora, IL 60505

ISBE ID	Sample Date	Sample Time (12 HR Clock)	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Concentration (µg/L)
310451310222013	11/04/2017	10:35 AM	OAKP-26B	1st Floor - Room 8 - Kindergarten Classroom	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:38 AM	OAKP-27A	1st Floor - Room 7 - Preschool Classroom	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:38 AM	OAKP-27B	1st Floor - Room 7 - Preschool Classroom	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:39 AM	OAKP-28A	1st Floor - Room 6 - Kindergarten Classroom	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:39 AM	OAKP-28B	1st Floor - Room 6 - Kindergarten Classroom	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:41 AM	OAKP-29A	1st Floor - Room 5 - Preschool Classroom	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:41 AM	OAKP-29B	1st Floor - Room 5 - Preschool Classroom	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:45 AM	OAKP-30A	1st Floor - Room 4 - Classroom Used for Storage	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:45 AM	OAKP-30B	1st Floor - Room 4 - Classroom Used for Storage	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:47 AM	OAKP-31A	1st Floor - Room 3 - Preschool Classroom	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:47 AM	OAKP-31B	1st Floor - Room 3 - Preschool Classroom	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:49 AM	OAKP-32A	1st Floor - Room 2 - Preschool Classroom	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:49 AM	OAKP-32B	1st Floor - Room 2 - Preschool Classroom	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:51 AM	OAKP-33A	1st Floor - Room 1 - Preschool Classroom	S - Sink	11/03/2017	07:00 PM	First Draw	6.04
310451310222013	11/04/2017	10:51 AM	OAKP-33B	1st Floor - Room 1 - Preschool Classroom	S - Sink	11/03/2017	07:00 PM	Flush	ND
310451310222013	11/04/2017	10:59 AM	OAKP-34A	1st Floor - Room 22 - Teachers' Work Room	S - Sink	11/03/2017	07:00 PM	First Draw	ND
310451310222013	11/04/2017	10:59 AM	OAKP-34B	1st Floor - Room 22 - Teachers' Work Room	S - Sink	11/03/2017	07:00 PM	Flush	ND

APPENDIX B
Laboratory Results and Chain of Custody Documentation

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

November 22, 2017

Olivia Reynhout
Weaver Consultants Group
1316 Bond St - Suite 108
Naperville, IL 60563

Workorder: 1711535

TEL: (630) 717-4848
FAX: (630) 717-4850

RE: Oak Park Elementary School School Drinking Water Lead Analysis

Dear Olivia Reynhout:

Suburban Laboratories, Inc. received 68 sample(s) on 11/7/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

A handwritten signature in black ink that reads "Pat Rodriguez".

Pat Rodriguez
Project Manager
708-544-3260 ext 214
pat@suburbanlabs.com

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
 Tel. (708) 544-3260 • Toll Free (800) 783-LABS
 Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Weaver Consultants Group

Project Name: Oak Park Elementary School School Drinking Water Lea

Report Date: November 22, 2017

Workorder: 1711535

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711535-001A	OAKP-01A~3rd Floor - Outside Room 302~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-002A	OAKP-01B~3rd Floor - Outside Room 302~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-003A	OAKP-02A~3rd Floor - Outside Room 303 - Social Worker's Bathroom~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-004A	OAKP-02B~3rd Floor - Outside Room 303 - Social Worker's Bathroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-005A	OAKP-03A~3rd Floor - Outside Room 307~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-006A	OAKP-03B~3rd Floor - Outside Room 307~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-007A	OAKP-04A~2nd Floor - Outside Room 203 - Nurse's Office~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-008A	OAKP-04B~2nd Floor - Outside Room 203 - Nurse's Office~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-009A	OAKP-05A~2nd Floor - Room 203 - Nurse's Office Bathroom~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-010A	OAKP-05B~2nd Floor - Room 203 - Nurse's Office Bathroom~Flush	2.65	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-011A	OAKP-06A~2nd Floor - Outside Room 208~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-012A	OAKP-06B~2nd Floor - Outside Room 208~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-013A	OAKP-07A~1st Floor - Outside Boy's Bathroom~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-014A	OAKP-07B~1st Floor - Outside Boy's Bathroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-015A	OAKP-08A~1st Floor - Kitchen~First Draw	5.30	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-016A	OAKP-08B~1st Floor - Kitchen~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-017A	OAKP-09A~1st Floor - Room 30~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-018A	OAKP-09B~1st Floor - Room 30~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017

ND - Not Detected Down to the Laboratory Minimum Reporting Limit (MRL)

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
 Tel. (708) 544-3260 • Toll Free (800) 783-LABS
 Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Weaver Consultants Group

Project Name: Oak Park Elementary School School Drinking Water Lea

Report Date: November 22, 2017

Workorder: 1711535

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711535-019A	OAKP-10A~1st Floor - Across from Girl's Bathroom (34)~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-020A	OAKP-10B~1st Floor - Across from Girl's Bathroom (34)~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-021A	OAKP-11A~1st Floor - Library Entryway (Left)~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-022A	OAKP-11B~1st Floor - Library Entryway (Left)~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-023A	OAKP-12A~1st Floor - Library Entryway (Right)~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-024A	OAKP-12B~1st Floor - Library Entryway (Right)~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-025A	OAKP-13A~1st Floor - Room 19 - Classroom~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-026A	OAKP-13B~1st Floor - Room 19 - Classroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-027A	OAKP-14A~1st Floor - Room 18 - Teachers' Lounge~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-028A	OAKP-14B~1st Floor - Room 18 - Teachers' Lounge~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-029A	OAKP-15A~1st Floor - Room 17 - 1st Grade Classroom~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-030A	OAKP-15B~1st Floor - Room 17 - 1st Grade Classroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-031A	OAKP-16A~1st Floor - Room 16 - Reading Interventionist~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-032A	OAKP-16B~1st Floor - Room 16 - Reading Interventionist~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-033A	OAKP-17A~1st Floor - Room 15 - Speech Pathologist~First Draw	11.4	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-034A	OAKP-17B~1st Floor - Room 15 - Speech Pathologist~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017

ND - Not Detected Down to the Laboratory Minimum Reporting Limit (MRL)

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
 Tel. (708) 544-3260 • Toll Free (800) 783-LABS
 Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Weaver Consultants Group

Project Name: Oak Park Elementary School School Drinking Water Lea

Report Date: November 22, 2017

Workorder: 1711535

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711535-035A	OAKP-18A~1st Floor - Room 14 - 2nd Grade Classroom~First Draw	4.05	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-036A	OAKP-18B~1st Floor - Room 14 - 2nd Grade Classroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-037A	OAKP-19A~1st Floor - Room 12 - 2nd Grade Classroom~First Draw	12.5	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-038A	OAKP-19B~1st Floor - Room 12 - 2nd Grade Classroom~Flush	8.81	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-039A	OAKP-20A~1st Floor - Outside Room 11 - Occupational and Physical Therapy (Left)~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-040A	OAKP-20B~1st Floor - Outside Room 11 - Occupational and Physical Therapy (Left)~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-041A	OAKP-21A~1st Floor - Outside Room 11 - Occupational and Physical Therapy (Right)~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-042A	OAKP-21B~1st Floor - Outside Room 11 - Occupational and Physical Therapy (Right)~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-043A	OAKP-22A~1st Floor - Room 10 - 2nd Grade Classroom~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-044A	OAKP-22B~1st Floor - Room 10 - 2nd Grade Classroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-045A	OAKP-23A~1st Floor - Between Boy's (9C) and Girl's (9D) Bathrooms (Left)~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-046A	OAKP-23B~1st Floor - Between Boy's (9C) and Girl's (9D) Bathrooms (Left)~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-047A	OAKP-24A~1st Floor - Between Boy's (9C) and Girl's (9D) Bathrooms (Right)~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-048A	OAKP-24B~1st Floor - Between Boy's (9C) and Girl's (9D) Bathrooms (Right)~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
 Tel. (708) 544-3260 • Toll Free (800) 783-LABS
 Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Weaver Consultants Group

Project Name: Oak Park Elementary School School Drinking Water Lea

Report Date: November 22, 2017

Workorder: 1711535

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711535-049A	OAKP-25A~1st Floor - Room 9 - Kindergarten Classroom~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-050A	OAKP-25B~1st Floor - Room 9 - Kindergarten Classroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-051A	OAKP-26A~1st Floor - Room 8 - Kindergarten Classroom~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-052A	OAKP-26B~1st Floor - Room 8 - Kindergarten Classroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-053A	OAKP-27A~1st Floor - Room 7 - Preschool Classroom~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-054A	OAKP-27B~1st Floor - Room 7 - Preschool Classroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-055A	OAKP-28A~1st Floor - Room 6 - Kindergarten Classroom~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-056A	OAKP-28B~1st Floor - Room 6 - Kindergarten Classroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-057A	OAKP-29A~1st Floor - Room 5 - Preschool Classroom~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-058A	OAKP-29B~1st Floor - Room 5 - Preschool Classroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-059A	OAKP-30A~1st Floor - Room 4 - Classroom Used for Storage~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-060A	OAKP-30B~1st Floor - Room 4 - Classroom Used for Storage~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-061A	OAKP-31A~1st Floor - Room 3 - Preschool Classroom~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-062A	OAKP-31B~1st Floor - Room 3 - Preschool Classroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-063A	OAKP-32A~1st Floor - Room 2 - Preschool Classroom~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-064A	OAKP-32B~1st Floor - Room 2 - Preschool Classroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017

ND - Not Detected Down to the Laboratory Minimum Reporting Limit (MRL)

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Weaver Consultants Group

Project Name: Oak Park Elementary School School Drinking Water Lea

Report Date: November 22, 2017

Workorder: 1711535

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711535-065A	OAKP-33A~1st Floor - Room 1 - Preschool Classroom~First Draw	6.04	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-066A	OAKP-33B~1st Floor - Room 1 - Preschool Classroom~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-067A	OAKP-34A~1st Floor - Room 22 - Teachers' Work Room~First Draw	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017
1711535-068A	OAKP-34B~1st Floor - Room 22 - Teachers' Work Room~Flush	ND	2.00	µg/L	11/03/2017 19:00	11/4/2017	11/11/2017

