Rollins Elementary School 950 Kane Street Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Room 15D	First Draw	ND
Room 15D	Flush	ND
Hallway Near 16W (Left)	First Draw	ND
Hallway Near 16W (Left)	Flush	ND
Hallway Near 16W (Right)	First Draw	ND
Hallway Near 16W (Right)	Flush	ND
Boiler Room (Non-Potable Source)	First Draw	363
Boiler Room (Non-Potable Source)	Flush	3.83
Room 12	First Draw	8.77
Room 12	Flush	ND
Room 10	First Draw	11.4
Room 10	Flush	ND
Room 22	First Draw	15.3
Room 22	Flush	3.03
Room 9	First Draw	13.1
Room 9	Flush	ND
Room 8	First Draw	15.3
Room 8	Flush	ND
Near Room 5	First Draw	ND
Near Room 5	Flush	ND
Near Room 5 (Bottle Filler)	First Draw	ND
Room 5	First Draw	10.1
Room 5	Flush	ND
Room 2	First Draw	6.02
Room 2	Flush	ND
Room 28	First Draw	5.12
Room 28	Flush	ND
Room 29	First Draw	17.2
Room 29	Flush	ND
Room 33	First Draw	ND
Room 33	Flush	ND
Room 30	First Draw	ND
Room 30	Flush	ND
Room 31	First Draw	ND
Room 31	Flush	ND

Rollins Elementary School 950 Kane Street Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Room 32	First Draw	ND
Room 32	Flush	ND
Near Room 122 (Left)	First Draw	ND
Near Room 122 (Left)	Flush	ND
Near Room 122 (Right)	First Draw	ND
Near Room 122 (Right)	Flush	ND
Near Room 120 (Left)	First Draw	ND
Near Room 120 (Left)	Flush	ND
Near Room 120 (Right)	First Draw	ND
Near Room 120 (Right)	Flush	ND
Room 120 - Nurse's Office	First Draw	ND
Room 120 - Nurse's Office	Flush	ND
Room 109	First Draw	7.85
Room 109	Flush	ND
Room 117	First Draw	17.4
Room 117	Flush	ND
Room 116	First Draw	56.1
Room 116	Flush	19.5
Room 115	First Draw	9.35
Room 115	Flush	ND
Room 114	First Draw	10.5
Room 114	Flush	ND
Room 111	First Draw	2.9
Room 111	Flush	ND
Room 112	First Draw	2.23
Room 112	Flush	ND
Room 103	First Draw	12.5
Room 103	Flush	ND
Room 101	First Draw	13.7
Room 101	Flush	ND
Room 102	First Draw	12.7
Room 102	Flush	ND
Room 131	First Draw	9.55
Room 131	Flush	ND
Room 132	First Draw	15

Rollins Elementary School 950 Kane Street Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Room 132	Flush	ND
Near Room 135 (Left)	First Draw	ND
Near Room 135 (Left)	Flush	ND
Near Room 135 (Right)	First Draw	ND
Near Room 135 (Right)	Flush	ND
Room 133	First Draw	ND
Room 133	Flush	ND
Room 134	First Draw	3.53
Room 134	Flush	ND
Room 135	First Draw	ND
Room 135	Flush	ND
Room 136	First Draw	ND
Room 136	Flush	ND

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing