



EAST AURORA
SCHOOL DISTRICT 131

BUILDINGS AND GROUNDS

411 Hill Ave • Aurora, IL 60505

d131.org • (630) 299-5548

5/20/2024

Bid Request

Fire Safety and Protection Services

Additional Information

Addendum # 1

There is 1 amendment and (6) six questions, with accompanying attachments, as part of this addendum. Please sign this document and include in your solicitation submission as acknowledgement of receipt and understanding.

Name of Company

Signature and Date

Reach your full potential!



Questions asked during Pre-Bid walk on 5/17/2024:

1. How many wet risers, dry risers, sectionals, standpipes, and pre-action systems are there per building? **See attached, "Exhibit – H".**
2. How often does the District want Hood and suppression Systems tested and can the previous reports be sent? **Semi-Annual/as recommended, see attached, "Exhibit – I".**
3. Can a cost sheet be provided to indicate individual pricing in the event there are more devices or testing needed than requested or specified? **Yes, individual services form provided and attached, "Exhibit B – Continued".**
4. Are there beam detectors, if so how many and what location(s)? **East Aurora High School has (2) two sets of beam detectors in the main gym.**
5. Is there alarm monitoring needed? **No.**
6. What type of Suppression system is at the Administrative Center? **There is a Sapphire Suppression system in (2) two server rooms with (5) five devices and (1) one tank.**



East Aurora School District 131 Bid #2024-11 Exhibit H

Fire Safety and Protection Services Bid

Quantity of Risers, Standpipes and Pre-action Systems per Building

	Location	Risers		Sectional	Standpipes	Pre-Action
		Wet	/ Dry			
1	Administrative Center	2	1	3	3	1
2	Allen Elementary	2				
3	Bardwell Elementary	N/A	N/A	N/A	N/A	N/A
4	Beaupre Elementary	1				
5	Benavides Steam Academy	1				
6	Brady Elementary	1				
7	Buildings and Grounds Center	N/A	N/A	N/A	N/A	N/A
8	Cowherd Middle School	2				
9	Dieterich Elementary	1				
10	Domeier Building	N/A	N/A	N/A	N/A	N/A
11	Early Childhood Center	1				
12	East Aurora Extension Campus	1				
13	East Aurora High School	10				2^
14	Fred Rogers Magnet Academy	3		3		
15	Gates Elementary	1	1			
16	Gonzales Child Center	1	1*			
17	Hermes Elementary	1				
18	Johnson Elementary	1				
19	Krug Elementary	1				
20	O'Donnell Elementary	1				
21	Oak Park Elementary	1				
22	Resilience Education Center	3	1	2		
23	Rollins Elementary	2	1			
24	Simmons Middle School	1			1	
25	Waldo Middle School	N/A	N/A	N/A	N/A	N/A
	Total	38	5	8	4	3

*Indicates Dry Nitrogen System

^Indicates dust collector Wet System



East Aurora School District 131 Bid #2024-11 Exhibit B - Continued

Fire Safety and Protection Services Bid

Base Bid Form Cost for Individual Services

	SERVICE	COST
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		